



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Chlorine

Day	pH	CaCO <sub>3</sub>	SiO <sub>2</sub>	Y/N
3/1	7.9	1.1		<del>Y</del>
3/2	7.9			Y
3/3	7.9			Y
3/5	7.8	1.2		Y
3/7	7.8			Y
3/8	7.9			Y
3/11	7.9	1.2		Y
3/12	7.9			Y
3/13	7.9			Y
3/16	7.8	1.2		Y
3/17	7.8			Y
3/18	7.8			Y
3/21	7.8	1.2		Y
3/22	7.9			Y
3/23	7.9			Y
3/24	7.9			Y
3/25	7.9	1.1		Y
3/28	7.7			
3/29	7.8			
3/31	7.9	1.1		

<<Have minimums been met for this day?

## ENTRY POINT

PWS ID: 41

System Name: Albany Trailer Court

Entry Point: Water Room

Sample Period: 3-23  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 3 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	<input type="text" value="7.2"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
SiO <sub>2</sub>	<input type="text"/>	(Silicate)

Print Name: Logan Levine

Signature: [Signature]

Date: 4-4-23

(No = N = Excursion) Total N's

Send to DHS within 10 days after end of sampling.  
14250 Portland, OR 97293-0350 Phone (503) 731-2222