

Albany

Day	pH	Temp	Clorox	Sili	Y/N
7/1	7.8		1		Y
7/2	7.8				Y
7/3	7.9				Y
7/6	7.9		1		Y
7/7	7.9				Y
7/8	7.9				Y
7/11	7.9		1.1		Y
7/12	8.0				Y
7/13	8.0				Y
7/16	8.0		1.1		Y
7/17	8.0				Y
7/18	8.0				Y
7/20	7.9		1.1		Y
7/22	7.9				Y
7/23	7.9				Y
7/26	7.9		1.1		Y
7/27	7.9				Y
7/28	7.9				Y
7/31	7.9		1.1		Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Albany Trailer Court

Entry Point: Water Room

Sample Period: 7-23
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 6 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

Print Name: Logan Zevane

Signature: Logan Zevane

Date: 8-4-23

(No = N = Excursion) Total N's:

Send to DHS within 10 days after end of sampling per