oregon department of human services

Lead & Copper Rule Corrosion Control

Day	pH	Temp	Chlorine $NaOCl_2$	Sili	Y/N
9-1	7.7		1.0		y
9-2	7.8				y
9-3	7.8				y
9-5	7.7		1.0		y
9-6	7.7				y
9-7	7.8				y
9-9	7.9		1.0		y
9-10	7.9		1.		y
9/11	7.9				y
9/13	7.9		1.1		y
9/14	8.0				y
9/15	8.0				y
9/18	8.0		1.1		y
9/19	7.9				y
9/20	7.9				y
9/23	7.9		1.0		y
9/24	7.8				y
9/25	7.9				y
9/28	7.9		1.0		y
9/29	7.9				y
9/30	7.9		1.0		y

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 0 0 4

System Name: Albany Trailer Court

Entry Point: Water Room

Sample Period: 9-23

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was le
than the minimum required)

Total excursions during the previous 5 months

(Over 9 excursions in 6 months is a violation. Ent
Point and Distribution excursions are cumulative

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.2	
Alk		(Alkalinity)
P04		(Orthophosphate)
Sili		(Silicate)

Print Name: Logan Levare

Signature: Logan Levare

Date: 10-4-23

Send to DHS within 10 days after end of sampli

[illegible] OR 97293-0350 Phone (503)