

Day	pH	Dist CaCO ₃	Sili	Y/N
10/1	7.9	1.0		Y
10/2	7.9			Y
10/3	7.9			Y
10/4	7.9	1.1		Y
10/7	7.8			Y
10/8	7.9			Y
10/11	7.9	1.1		Y
10/12	7.9			Y
10/13	7.9			Y
10/16	7.7	1.0		Y
10/17	7.7			Y
10/18	7.8			Y
10/21	7.9	1.0		Y
10/22	7.9			Y
10/23	7.9			Y
10/26	7.8	1.0		Y
10/27	7.8			Y
10/28	7.8			Y
10/31	7.9	1.0		Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Albany Trailer Court

Entry Point: Water Room

Sample Period: 10-23
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Logan LeVane

Signature: Logan LeVane

Date: 11-5-23

(No = N = Excursion) Total N's

Send to DHS within 10 days after end of sampling