

Day	pH	CaCO ₃	Sili	Y/N
12/1	7.8	1.0		y
12/2	7.9	1.0		y
12/3	7.9	1.1		y
12/4	7.9	1.1		y
12/7	7.9	0.9		y
12/8	8.0			y
12/11	8.0	0.7		y
12/12	7.9			y
12/13	7.8	0.8		y
12/16	7.8			y
12/17	7.8			y
12/18	7.8	0.8		y
12/20	7.7			y
12/22	7.7			y
12/23	7.7	0.8		y
12/26	7.8			y
12/27	7.9			y
12/28	7.8	0.8		y
12/31	7.8	0.8		y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 [][][][]

System Name: Albany Trailer Court

Entry Point: Water Room

Sample Period: 12-23 Month/Year

Number of excursions* during this mo (Count the number of days when any W than the minimum required)

Total excursions during the previous 5 (Over 9 excursions in 6 months is a viola Point and Distribution excursions are cu

For DHS use only

Minimum Water Quality Parameters as set by S

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthoph)
Sili		(Silicate)

Print Name: Mequan M'G
Signature: [Signature]
Date: 12/31/24

(No = N = Excursion) Total N's [0]

Send to DHS within 10 days after enr