Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Chlorine

Day	pH	[illegible]	$CaCO_3$	Sili	Y/N
2/2	7.3				Y
2/4	7.5	.9			Y
2/6	7.6				Y
2/8	7.8	.8			Y
2/10	7.6				Y
2/12	7.6	0.7			Y
2/14	7.5				Y
2/16	7.4	0.9			Y
2/18	7.5				Y
2/20	7.5	0.9			Y
2/22	7.6				Y
2/24	7.4				Y
2/26	7.5				Y
2/28	7.4	1.2			Y

<<Have minimums been met for this day?

(No = N = Excursion) Total #= [ ]

ENTRY POINT

PWS ID: 41 0 0 0 0 4

System Name: Albany Trailer Court

Entry Point: Water room

Sample Period: 2/2024
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Megan McGaughy

Signature: Megan McGaughy

Date: 2/28/2024

Send to DHS within 10 days after end of sampling per

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-42