DHS Oregon Department of Human Services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	chlorine [redacted]	$CaCO_3$	Sili	Y/N
3/1	7.5	1.1			y
3/3	7.4	1.1			y
3/5	7.4	.9			y
3/7	7.6	.9			y
3/9	7.6	.8			y
3/11	7.8	0.9			y
3/13	7.5	0.7			y
3/15	7.4	0.7			y
3/17	7.8	0.8			y
3/19	7.5	0.6			y
3/21	7.6	1.1			y
3/23	7.5	1.2			y
3/25	7.5	0.8			y
3/27	7.4	1.1			y
3/29	7.4	1			y
3/31	7.6	1			y

<<Have minimums been met for this day?

(No = N = Excursion) **Total N's** 0

ENTRY POINT

PWS ID: 41 0 0 0 0 4

System Name: Albany Trailer Court

Entry Point: water room

Sample Period: 3/2024
Month/Year

Number of excursions* during this month: ____

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.2	
Alk		(Alkalinity)
P04		(Orthophosphate)
Sili		(Silicate)

Print Name: Megan M'Gaughy

Signature: Megan M'Gaughy

Date: 3/31/2024

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381