DHS Oregon Department of Human Services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Chlorine

Day	pH	[redacted]	$CaCO_3$	Sili	Y/N
4/2	7.4	1			Y
4/4	7.6	0.7			Y
4/6	7.8	0.8			Y
4/8	7.5	0.6			Y
4/10	7.4	0.5			Y
4/12	7.6	0.8			Y
4/14	7.4	1			Y
4/16	7.5	0.9			Y
4/18	7.9	0.8			Y
4/20	7.7	1			Y
4/22	7.6	1			Y
4/24	7.5	1.1			Y
4/26	7.6	1.0			Y
4/28	7.8	1.0			Y

(No = N = Excursion) Total N's: N

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 0 0 4

System Name: Albany Trailer Court

Entry Point: Water room

Sample Period: 4/2024
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.2	
Alk		*(Alkalinity)*
PO4		*(Orthophosphate)*
Sili		*(Silicate)*

Print Name: Megan McGaughey

Signature: Megan McGaughey

Date: 4/30/2024

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381