



Lead & Copper Rule Corrosion Control

Chlorine

Day	pH	Cl ₂	CaCO ₃	Sili	Y/N
5/2	7.5	1			y
5/4	7.6	0.9			y
5/6	7.6	0.8			y
5/8	7.4	0.9			y
5/10	7.5	0.7			y
5/12	7.6	0.8			y
5/14	7.4	1			y
5/16	7.6	1			y
5/18	7.5	0.9			y
5/20	7.5	0.9			y
5/22	7.6	0.9			y
5/24	7.6	.8			y
5/26	7.6	.8			y
5/28	7.5	0.9			y
5/30	7.7	0.9			y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 4

System Name: Albany Trailer Court
Entry Point: Water room
Sample Period: 5/2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

Print Name: Megan McGrawany
Signature: Megan McGrawany
Date: 5/31/2024

(No = N = Excursion) Total N's: 0

Send to DHS within 10 days after end of sampling period