



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Chlorine	CaCO ₃	Sili	Y/N
6/1	7.6	0.7			y
6/3	7.6	0.6			y
6/5	7.7	0.8			y
6/7	7.7	0.8			y
6/9	7.8	0.9			y
6/11	7.6	0.7			y
6/13	7.4	0.8			y
6/15	7.7	0.8			y
6/17	7.8	0.7			y
6/19	7.5	0.7			y
6/21	7.7	0.8			y
6/23	7.5	0.9			y
6/25	7.6	0.9			y
6/27	7.8	0.8			y
6/29	7.7	0.7			y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Albany Trailer Court

Entry Point: Water room

Sample Period: 6/2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	<input type="text" value="7.2"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Sili	<input type="text"/>	(Silicate)

Print Name: Megan McGaughy
Signature: Megan McGaughy
Date: 7/1/2024

(No = N = Excursion) Total N's: 0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381