



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	CaCO <sub>3</sub>	Site	Y/N
8/2	7.8	1.0		Y
8/4	7.6	0.9		Y
8/6	7.8	0.8		Y
8/8	7.9	0.9		Y
8/10	7.8	0.8		Y
8/12	7.9	0.7		Y
8/14	7.9	0.8		Y
8/16	7.7	0.7		Y
8/18	7.9	0.8		Y
8/20	7.8	0.7		Y
8/22	8.0	1		Y
8/24	8.0	1		Y
8/26	7.8	0.9		Y
8/28	7.7	0.8		Y
8/30	7.7	0.8		Y

Chlorine

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41     4

System Name: Albany Trailer Court

Entry Point: Water room

Sample Period: 8/2024  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.2
Alk	(Alkalinity)
PO <sub>4</sub>	(Orthophosphate)
Sili	(Silicate)

Print Name: Jack Loyd

Signature: Jack Loyd

Date: 8/30/24

(No = N = Excursion) Total N's

Send to DHS within 10 days after end of sampling period