



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Chlorine

Day	pH	Cl <sub>2</sub>	CaCO <sub>3</sub>	Sili	Y/N
12/2	7.8	1			Y
12/4	7.9	1			Y
12/6	7.8	0.9			Y
12/8	7.8	1			Y
12/10	7.7	1			Y
12/12	7.7	1.1			Y
12/14	7.6	1.1			Y
12/16	7.8	1			Y
12/18	7.8	0.9			X
12/20	7.7	0.8			X
12/22	7.6	0.8			X
12/24	7.8	0.9			Y
12/26	7.8	0.9			Y
12/28	7.7	1.0			X
12/30	7.8	1.1			X

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 0 0 0 0 4

System Name: Albany Trailer Court

Entry Point: Water room

Sample Period: December 1 2024  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions\* during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

Print Name: Jack Loyd

Signature: Jack Loyd

Date: 12/31/2024

(No = N = Excursion) Total N's: 0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381