DHS
oregon department of human services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Chlorie [redacted]	$CaCO_3$	Sili	Y/N
1/1	7.7	1			Y
1/3	7.6	0.8			Y
1/4	7.8	0.9			Y
1/6	7.9	1			Y
1/8	7.8	0.9			Y
1/10	7.8	0.9			Y
1/12	7.9	0.9			Y
1/14	7.7	0.8			Y
1/16	7.8	0.9			Y
1/18	7.7	1			Y
1/20	7.7	0.9			Y
1/22	7.8	1			Y
1/24	7.8	1			Y
1/26	7.8	0.9			Y
1/28	7.9	1			Y
1/30	7.8	1			Y

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 0 0 4

System Name: Albany Trailer Court

Entry Point: Water shed

Sample Period: January, 2025
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Megan M'Gawghy

Signature: Megan M'Gawghy

Date: 2/12/2025

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381