

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1 | 7 | .9 | | | y |
| 2 | 7.0 | | | | |
| 3 | 7.2 | .7 | | | y |
| 4 | | | | | |
| 5 | 7.3 | .5 | | | y |
| 6 | | | | | |
| 7 | 7.2 | .5 | | | y |
| 8 | | | | | |
| 9 | 7.2 | .6 | | | y |
| 10 | | | | | |
| 11 | 7.2 | .5 | | | y |
| 12 | | | | | |
| 13 | 7.2 | .6 | | | y |
| 14 | | | | | |
| 15 | 7.2 | .5 | | | y |
| 16 | | | | | |
| 17 | 7.2 | .6 | | | y |
| 18 | | | | | |
| 19 | 7.2 | .6 | | | y |
| 20 | | | | | |
| 21 | 7.2 | .5 | | | y |
| 22 | | | | | |
| 23 | 7.2 | .6 | | | y |
| 24 | | | | | |
| 25 | 7.2 | .6 | | | y |
| 26 | | | | | |
| 27 | 7 | .6 | | | y |
| 28 | | | | | |
| 29 | 7.2 | .5 | | | y |
| 30 | | | | | |
| 31 | 7.2 | .6 | | | y |

(No = N = Excursion) Total N's

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 4

System Name: Albany Trailer w/ RV Park

Entry Point: Water Sheld

Sample Period: 5/25



Month/Year

Number of excursions* during this month: _____

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality
Parameters as set by

| | | |
|-------|--------------------------|------------------|
| pH | <input type="checkbox"/> | (Alkalinity) |
| Alk | <input type="checkbox"/> | (Orthophosphate) |
| PO4 | <input type="checkbox"/> | (|
| Other | <input type="checkbox"/> |) |

Print Name: Logan LaVigne

Signature: Logan LaVigne

Date: 5/31/2025

Send to DWP within 10 days after end of
sampling period