

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.32	OFF			Y
2	8.32	OFF			Y
3	8.33	OFF			Y
4	8.31	OFF			Y
5	8.31	OFF			Y
6	8.28	OFF			Y
7	8.25	OFF			Y
8	8.23	OFF			Y
9	8.20	OFF			Y
10	8.17	OFF			Y
11	8.17	OFF			Y
12	8.20	OFF			Y
13	8.21	OFF			Y
14	8.23	OFF			Y
15	8.23	OFF			Y
16	8.22	OFF			Y
17	8.21	OFF			Y
18	8.20	OFF			Y
19	8.21	OFF			Y
20	8.23	OFF			Y
21	8.25	OFF			Y
22	8.26	OFF			Y
23	8.29	OFF			Y
24	8.32	OFF			Y
25	8.32	OFF			Y
26	8.31	OFF			Y
27	8.29	OFF			Y
28	8.27	OFF			Y
29	8.23	OFF			Y
30	8.22	OFF			Y
31	8.22	OFF			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: January 2021

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chuck Leffler

Signature: 

Date & Phone#: 2-3-21, 541-990-1907

Plant Offline 12/17 Upgrade Proj.

Send to DWP within 10 days after end of sample period