



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.22	OFF			Y
2	8.22	OFF			Y
3	8.20	OFF			Y
4	8.18	OFF			Y
5	8.15	OFF			Y
6	8.14	OFF			Y
7	8.16	OFF			Y
8	8.22	OFF			Y
9	8.28	OFF			Y
10	8.30	OFF			Y
11	8.29	OFF			Y
12	8.26	OFF			Y
13	8.27	OFF			Y
14	8.26	OFF			Y
15	8.23	OFF			Y
16	8.23	OFF			Y
17	8.30	OFF			Y
18	8.35	OFF			Y
19	8.34	OFF			Y
20	8.30	OFF			Y
21	8.27	OFF			Y
22	8.27	OFF			Y
23	8.26	OFF			Y
24	8.26	OFF			Y
25	8.27	OFF			Y
26	8.26	OFF			Y
27	8.23	OFF			Y
28	8.28	OFF			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: February 2021

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chuck Leffler

Signature:

Date & Phone#: 3-3-21, 541-990-1907

Send to DWP within 10 days after end of sample period