



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	8.33	OFF			Y
2	8.34	OFF			Y
3	8.30	OFF			Y
4	8.26	OFF			Y
5	8.24	OFF			Y
6	8.24	OFF			Y
7	8.24	OFF			Y
8	8.26	OFF			Y
9	8.27	OFF			Y
10	8.25	OFF			Y
11	8.24	OFF			Y
12	8.24	OFF			Y
13	8.27	OFF			Y
14	8.28	OFF			Y
15	8.28	OFF			Y
16	8.28	OFF			Y
17	8.28	OFF			Y
18	8.30	OFF			Y
19	8.33	OFF			Y
20	8.30	OFF			Y
21	8.29	OFF			Y
22	8.31	OFF			Y
23	8.31	OFF			Y
24	8.32	OFF			Y
25	8.32	OFF			Y
26	8.33	OFF			Y
27	8.30	OFF			Y
28	8.30	OFF			Y
29	8.33	OFF			Y
30	8.31	OFF			Y
31	8.27	OFF			Y

<<Have minimums been met for this day?

<p><b>ENTRY POINT</b>  <b>PWS ID: 4100012 A</b>  <b>System Name: Albany</b>  <b>Entry Point: Vine Street Drinking Water Plant</b>  <b>Sample Period: March 2021</b>  <b>Month/Year</b></p>
--

**Number of excursions\* during this month: 0**

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months: 0**

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

<p>For DHS use only</p> <p><b>Minimum Water Quality Parameters as set by State:</b></p> <p>pH <input type="text" value="7.8"/></p> <p>Alk <input type="text" value="18.0"/> (Alkalinity)</p> <p>PO4 <input type="text"/> (Orthophosphate)</p> <p>Sili <input type="text"/> (Silicate)</p>
---

**Print Name:** Chuck Leffler

**Signature:**

**Date & Phone#:** 4-2-21, 541-990-1907