



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Sili | Y/N |
|-----|------|-----|------|------|-----|
| 1 | 8.27 | OFF | | | Y |
| 2 | 8.31 | OFF | | | Y |
| 3 | 8.30 | OFF | | | Y |
| 4 | 8.27 | OFF | | | Y |
| 5 | 8.23 | OFF | | | Y |
| 6 | 8.24 | OFF | | | Y |
| 7 | 8.24 | OFF | | | Y |
| 8 | 8.28 | OFF | | | Y |
| 9 | 8.22 | OFF | | | Y |
| 10 | 8.21 | OFF | | | Y |
| 11 | 8.20 | OFF | | | Y |
| 12 | 8.20 | OFF | | | Y |
| 13 | 8.16 | OFF | | | Y |
| 14 | 8.16 | OFF | | | Y |
| 15 | 8.09 | OFF | | | Y |
| 16 | 8.06 | OFF | | | Y |
| 17 | 8.03 | OFF | | | Y |
| 18 | 8.02 | OFF | | | Y |
| 19 | 8.06 | OFF | | | Y |
| 20 | 8.06 | OFF | | | Y |
| 21 | 8.02 | OFF | | | Y |
| 22 | 8.00 | OFF | | | Y |
| 23 | 8.02 | OFF | | | Y |
| 24 | 8.02 | OFF | | | Y |
| 25 | 8.03 | OFF | | | Y |
| 26 | 8.01 | OFF | | | Y |
| 27 | 7.99 | OFF | | | Y |
| 28 | 7.96 | OFF | | | Y |
| 29 | 7.96 | OFF | | | Y |
| 30 | 7.98 | OFF | | | Y |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: April 2021

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:


pH 7.8

Alk 18.0 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chuck LePier

Signature: 

Date & Phone#: 5-10-21, 541-990-1907