



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.99	OFF			Y
2	8.01	OFF			Y
3	7.99	OFF			Y
4	7.96	OFF			Y
5	7.96	OFF			Y
6	7.92	OFF			Y
7	7.91	OFF			Y
8	7.92	OFF			Y
9	7.96	OFF			Y
10	7.98	OFF			Y
11	7.99	OFF			Y
12	8.07	OFF			Y
13	8.03	OFF			Y
14	8.02	OFF			Y
15	8.03	OFF			Y
16	8.03	OFF			Y
17	8.01	OFF			Y
18	7.98	OFF			Y
19	7.98	OFF			Y
20	7.98	OFF			Y
21	8.00	OFF			Y
22	8.02	OFF			Y
23	8.05	OFF			Y
24	8.08	OFF			Y
25	8.04	OFF			Y
26	8.07	OFF			Y
27	8.07	OFF			Y
28	8.11	OFF			Y
* 29	8.11	OFF			Y
30	8.16	25.7			Y
31	8.17	29.8			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: May 2021

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

* Plant offline 5/1-5/28. Plant began filtering 5/29 but did not distribute to system until 5/30. gr 6/10/21

Print Name: Siou LaRoque, Water Superintendent

Signature: [Signature]

Date & Phone#: 6/10/21, 541 791 0175

Send to DWP within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405