



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.31	25.3			Y
2	8.27	25.1			Y
3	8.22	24.3			Y
4	8.25	24.5			Y
5	8.32	24.0			Y
6	8.34	29.0			Y
7	8.37	22.0			Y
8	8.37	26.5			Y
9	8.44	23.8			Y
10	8.43	23.9			Y
11	8.43	24.0			Y
12	8.41	24.3			Y
13	8.38	OFF			Y
14	8.26	29.6			Y
15	8.27	OFF			Y
16	8.28	24.2			Y
17	8.29	24.9			Y
18	8.32	24.3			Y
19	8.27	24.1			Y
20	8.38	24.1			Y
21	8.30	27.6			Y
22	8.19	23.6			Y
23	8.20	23.5			Y
24	8.23	25.5			Y
25	8.27	25.1			Y
26	8.30	25.3			Y
27	8.25	24.4			Y
28	8.21	27.5			Y
29	8.17	29.4			Y
30	8.25	25.2			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: June 2021

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chuck Lettler

Signature:

Date & Phone#: 7-7-21, 591-990-1907