



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	8.30	24.1			Y
2	8.31	25.5			Y
3	8.30	24.0			Y
4	8.26	24.9			Y
5	8.24	33.6			Y
6	8.31	22.1			Y
7	8.31	24.1			Y
8	8.36	23.9			Y
9	8.37	24.7			Y
10	8.33	26.5			Y
11	8.31	22.1			Y
12	8.33	24.0			Y
13	8.25	25.2			Y
14	8.17	24.7			Y
15	8.17	25.2			Y
16	8.22	26.8			Y
17	8.24	24.3			Y
18	8.21	22.8			Y
19	8.19	27.0			Y
20	8.20	23.7			Y
21	8.23	25.0			Y
22	8.21	25.4			Y
23	8.18	24.9			Y
24	8.15	24.7			Y
25	8.19	31.0			Y
26	8.18	26.3			Y
27	8.17	32.4			Y
28	8.11	27.7			Y
29	8.15	27.2			Y
30	8.17	27.8			Y
31	8.12	26.4			Y

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: July 2021

Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality**

Parameters as set by State:

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

Print Name: Chuck Leffler

Signature:

Date & Phone#: 8-9-21, 541-990-1907