



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	8.28	27.2			Y
2	8.16	25.9			Y
3	8.24	26.3			Y
4	8.21	28.5			Y
5	8.13	27.6			Y
6	8.25	25.0			Y
7	8.26	25.4			Y
8	8.21	30.0			Y
9	8.23	24.9			Y
10	8.28	32.5			Y
11	8.33	25.0			Y
12	8.20	25.6			Y
13	8.20	28.4			Y
14	8.23	28.8			Y
15	8.21	29.2			Y
16	8.14	29.9			Y
17	8.19	24.9			Y
18	8.25	28.4			Y
19	8.30	24.7			Y
20	8.28	26.9			Y
21	8.22	26.3			Y
22	8.19	32.5			Y
23	8.23	27.0			Y
24	8.28	28.2			Y
25	8.27	26.0			Y
26	8.18	28.0			Y
27	8.07	28.5			Y
28	8.07	26.2			Y
29	8.08	30.7			Y
30	8.12	27.5			Y
31	8.11	26.7			Y

<<Have minimums been met for this day?

**ENTRY POINT**

**PWS ID: 4100012 A**

**System Name:** Albany

**Entry Point:** Vine Street Drinking Water Plant

**Sample Period:** August 2021

Month/Year

**Number of excursions\* during this month:** 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

**Print Name:** Chad Leffler

**Signature:**

**Date & Phone#:** 9-3-21, 541-990-1907