



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.15	26.7			Y
2	8.17	25.8			Y
3	8.16	28.8			Y
4	8.15	26.0			Y
5	8.15	26.5			Y
6	8.11	24.6			Y
7	8.10	27.9			Y
8	8.11	27.0			Y
9	8.12	25.3			Y
10	8.12	26.4			Y
11	8.20	26.2			Y
12	8.27	27.9			Y
13	8.28	25.6			Y
14	8.28	25.5			Y
15	8.25	29.6			Y
16	8.24	25.4			Y
17	8.28	27.1			Y
18	8.27	26.9			Y
19	8.19	29.4			Y
20	8.14	27.2			Y
21	8.14	26.1			Y
22	8.08	28.2			Y
23	8.08	27.7			Y
24	8.07	30.0			Y
25	8.08	26.9			Y
26	8.07	28.6			Y
27	8.03	27.3			Y
28	8.09	26.9			Y
29	8.14	27.6			Y
30	8.14	25.4			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: September 2021

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Scott LaRaque, Water Superintendent

Signature: 

Date & Phone#: 10/8/21, 541-791-0775