



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.11	26.9			Y
2	8.12	30.6			Y
3	8.12	26.7			Y
4	8.10	26.0			Y
5	8.09	29.0			Y
6	8.13	27.3			Y
7	8.19	29.2			Y
8	8.22	31.5			Y
9	8.25	27.5			Y
10	8.26	27.4			Y
11	8.21	26.4			Y
12	8.16	26.0			Y
13	8.15	OFF			Y
14	8.12	29.4			Y
15	8.14	25.3			Y
16	8.08	28.4			Y
17	8.12	28.7			Y
18	8.09	27.6			Y
19	8.11	19.7			Y
20	8.11	OFF			Y
21	8.15	OFF			Y
22	8.16	28.9			Y
23	8.32	OFF			Y
24	8.25	25.2			Y
25	8.16	25.7			Y
26	8.16	25.8			Y
27	8.12	26.4			Y
28	8.14	23.6			Y
29	8.06	28.7			Y
30	8.05	29.2			Y
31	8.12	29.4			Y

<<Have minimums been met for this day?

ENTRY POINT
PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: October 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality
Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chuck Leffler

Signature:

Date & Phone#: 11-10-21, 541-990-1907