



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.18	29.6			Y
2	8.18	27.5			Y
3	8.18	OFF			Y
4	8.12	26.9			Y
5	8.06	28.4			Y
6	8.14	OFF			Y
7	8.16	29.7			Y
8	8.06	28.9			Y
9	8.04	30.1			Y
10	8.12	26.8			Y
11	8.17	26.8			Y
12	8.14	OFF			Y
13	8.11	27.4			Y
14	8.15	28.8			Y
15	8.17	25.5			Y
16	8.13	OFF			Y
17	8.12	OFF			Y
18	8.17	25.9			Y
19	8.21	25.6			Y
20	8.21	25.4			Y
21	8.22	28.9			Y
22	8.24	25.0			Y
23	8.24	29.0			Y
24	8.25	OFF			Y
25	8.23	27.1			Y
26	8.24	26.3			Y
27	8.22	25.0			Y
28	8.16	29.7			Y
29	8.16	26.4			Y
30	8.21	25.1			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: November 2021

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chuck Leffler

Signature:

Date & Phone#: 12-10-21 , 541-990-1907