



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.23	OFF			Y
2	8.24	25.5			Y
3	8.34	24.9			Y
4	8.39	26.0			Y
5	8.43	30.1			Y
6	8.43	27.9			Y
7	8.40	24.7			Y
8	8.31	OFF			Y
9	8.26	25.3			Y
10	8.25	25.8			Y
11	8.29	28.2			Y
12	8.28	25.6			Y
13	8.23	29.9			Y
14	8.18	25.4			Y
15	8.22	OFF			Y
16	8.20	24.8			Y
17	8.30	26.7			Y
18	8.36	28.1			Y
19	8.33	28.1			Y
20	8.25	28.1			Y
21	8.21	23.2			Y
22	8.16	27.0			Y
23	8.02	OFF			Y
24	8.04	OFF			Y
25	8.05	OFF			Y
26	8.05	OFF			Y
27	8.09	OFF			Y
28	8.18	25.9			Y
29	8.29	OFF			Y
30	8.25	OFF			Y
31	8.28	24.3			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: December 2021

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:


pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chuck Leffler

Signature: 

Date & Phone#: 1-6-22, 541-990-1907