



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.33	25.7			Y
2	8.36	22.2			Y
3	8.37	OFF			Y
4	8.28	24.1			Y
5	8.30	OFF			Y
6	8.28	22.7			Y
7	8.15	23.8			Y
8	8.04	26.7			Y
9	8.07	20.9			Y
10	8.15	21.0			Y
11	8.23	OFF			Y
12	8.21	20.2			Y
13	8.22	24.1			Y
14	8.24	23.8			Y
15	8.31	OFF			Y
16	8.35	OFF			Y
17	8.24	OFF			Y
18	8.19	OFF			Y
19	8.31	21.5			Y
20	8.31	OFF			Y
21	8.18	22.6			Y
22	8.13	OFF			Y
23	8.13	OFF			Y
24	8.15	OFF			Y
25	8.19	21.4			Y
26	8.18	20.5			Y
27	8.20	OFF			Y
28	8.20	25.4			Y
29	8.21	22.2			Y
30	8.23	21.9			Y
31	8.21	21.4			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: January 2022

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chuck Leffler

Signature:

Date & Phone#: 2-4-22, 541-990-1907