



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.26	20.2			Y
2	8.26	20.9			Y
3	8.23	23.0			Y
4	8.17	21.0			Y
5	8.18	24.0			Y
6	8.22	22.1			Y
7	8.17	21.9			Y
8	8.13	24.6			Y
9	8.17	OFF			Y
10	8.13	24.5			Y
11	8.11	21.6			Y
12	8.19	22.9			Y
13	8.19	OFF			Y
14	8.21	OFF			Y
15	8.19	OFF			Y
16	8.27	22.7			Y
17	8.25	23.0			Y
18	8.25	OFF			Y
19	8.30	OFF			Y
20	8.29	21.5			Y
21	8.26	20.5			Y
22	8.23	OFF			Y
23	8.22	23.8			Y
24	8.25	23.3			Y
25	8.31	24.6			Y
26	8.34	OFF			Y
27	8.36	22.8			Y
28	8.34	OFF			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: February 2022

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chuck Leffler

Signature:

Date & Phone#: 3/9/22, 541-990-1907