

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.20	25.2			Y
2	8.05	23.3			Y
3	8.06	24.3			Y
4	8.10	OFF			Y
5	8.13	23.5			Y
6	8.12	OFF			Y
7	8.11	23.8			Y
8	8.06	22.4			Y
9	7.96	24.9			Y
10	8.02	OFF			Y
11	8.01	OFF			Y
12	7.99	OFF			Y
13	7.99	OFF			Y
14	8.06	OFF			Y
15	8.06	OFF			Y
16	8.06	23.9			Y
17	8.12	25.5			Y
18	8.25	25.6			Y
19	8.29	24.5			Y
20	8.30	OFF			Y
21	8.24	24.8			Y
22	8.19	24.7			Y
23	8.14	25.6			Y
24	8.11	23.8			Y
25	8.07	23.4			Y
26	8.04	23.3			Y
27	8.03	23.4			Y
28	8.10	24.1			Y
29	8.04	25.5			Y
30	8.08	23.7			Y
31	8.12	OFF			Y

<<Have minimums been met for this day?

ENTRY POINT
PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: May 2022
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality
Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphosphate)

Sili (Silicate)

Print Name: Chuck Heffler

Signature: 

Date & Phone#: 6-3-22, 541-990-1907