

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.00	29.1			Y
2	7.92	25.5			Y
3	7.99	27.1			Y
4	8.06	27.1			Y
5	8.07	25.5			Y
6	8.09	26.2			Y
7	8.08	27.9			Y
8	8.10	26.3			Y
9	8.13	27.2			Y
10	8.12	25.6			Y
11	8.13	25.9			Y
12	8.09	27.4			Y
13	7.96	25.6			Y
14	7.95	29.0			Y
15	8.00	27.0			Y
16	8.03	28.9			Y
17	8.03	26.8			Y
18	8.01	25.0			Y
19	8.12	25.0			Y
20	8.08	26.7			Y
21	8.01	27.0			Y
22	8.02	27.4			Y
23	8.03	27.5			Y
24	8.07	27.0			Y
25	8.13	25.3			Y
26	8.02	27.0			Y
27	7.97	26.8			Y
28	8.10	27.0			Y
29	8.20	27.5			Y
30	8.16	24.9			Y
31	8.18	27.4			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: July 2022

 Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:


pH

Alk (Alkalinity)

PO4 (Orthophosphosphate)

Sili (Silicate)

Print Name: Chad Lettler

Signature: 

Date & Phone#: 8-10-22, 541-990-1907