



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.16	26.6			Y
2	8.21	27.0			Y
3	8.18	26.0			Y
4	8.16	25.0			Y
5	8.17	25.8			Y
6	8.14	26.5			Y
7	8.15	27.0			Y
8	8.13	23.9			Y
9	8.14	24.0			Y
10	8.12	23.6			Y
11	8.16	25.4			Y
12	8.07	24.9			Y
13	8.23	26.6			Y
14	8.25	26.0			Y
15	8.16	28.1			Y
16	8.18	25.0			Y
17	8.21	26.8			Y
18	8.09	24.8			Y
19	8.06	25.0			Y
20	8.17	26.2			Y
21	8.21	24.3			Y
22	8.09	25.5			Y
23	8.17	26.3			Y
24	8.11	25.3			Y
25	8.10	30.2			Y
26	7.94	26.5			Y
27	7.94	26.2			Y
28	8.05	26.3			Y
29	8.11	24.7			Y
30	8.08	24.0			Y
31	7.94	23.6			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: August 2022

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphosphate)

Sili (Silicate)

Print Name: Chuck Leffler

Signature:

Date & Phone#: 8-2-22, 541-790-1907