



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.03	24.8			Y
2	7.94	25.7			Y
3	7.83	25.9			Y
4	7.95	25.9			Y
5	7.83	26.7			Y
6	8.34	27.0			Y
7	8.35	27.6			Y
8	8.37	27.2			Y
9	8.34	24.9			Y
10	8.30	25.5			Y
11	8.33	26.2			Y
12	8.38	27.7			Y
13	8.40	27.9			Y
14	8.37	23.0			Y
15	8.41	OFF			Y
16	8.35	23.9			Y
17	8.28	24.3			Y
18	8.26	24.7			Y
19	8.28	18.0			Y
20	8.34	OFF			Y
21	8.33	24.1			Y
22	8.24	26.9			Y
23	8.21	OFF			Y
24	8.21	21.7			Y
25	8.26	22.1			Y
26	8.19	OFF			Y
27	8.24	26.0			Y
28	8.19	23.0			Y
29	8.20	26.0			Y
30	8.19	26.3			Y
31	8.12	22.7			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: October 2022
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chuck Leffler

Signature:

Date & Phone#: 11-8-22, 541-990-1907