

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.06	22.8			Y
2	8.02	23.5			Y
3	8.07	OFF			Y
4	8.13	OFF			Y
5	8.07	24.0			Y
6	8.13	OFF			Y
7	8.06	22.6			Y
8	8.05	OFF			Y
9	7.97	22.0			Y
10	8.03	OFF			Y
11	8.00	23.1			Y
12	7.99	OFF			Y
13	7.97	20.7			Y
14	7.92	21.4			Y
15	7.87	24.3			Y
16	7.88	22.3			Y
17	7.91	OFF			Y
18	7.90	25.2			Y
19	7.86	25.1			Y
20	7.86	23.2			Y
21	7.94	23.0			Y
22	7.87	OFF			Y
23	7.99	23.6			Y
24	8.10	24.0			Y
25	8.02	24.2			Y
26	8.09	OFF			Y
27	8.12	23.4			Y
28	8.00	24.2			Y
29	8.06	OFF			Y
30	8.08	OFF			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: November 2022

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphosphate)

Sili (Silicate)

Print Name: Chuck Leffler

Signature: 

Date & Phone#: 12-8-22, 541-990-1907