



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.03	OFF			Y
2	8.18	27.9			Y
3	8.34	25.4			Y
4	8.50	25.6			Y
5	8.42	22.9			Y
6	8.36	25.1			Y
7	8.34	OFF			Y
8	8.36	OFF			Y
9	8.39	OFF			Y
10	8.42	24.0			Y
11	8.39	22.8			Y
12	8.32	22.6			Y
13	8.36	OFF			Y
14	8.48	OFF			Y
15	8.52	OFF			Y
16	8.51	24.0			Y
17	8.49	OFF			Y
18	8.46	25.1			Y
19	8.42	OFF			Y
20	8.43	23.8			Y
21	8.36	OFF			Y
22	8.34	OFF			Y
23	8.43	OFF			Y
24	8.50	OFF			Y
25	8.50	25.2			Y
26	8.46	OFF			Y
27	8.43	23.5			Y
28	8.24	20.6			Y
29	8.19	20.2			Y
30	8.18	22.5			Y
31	8.20	OFF			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: December 2022

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chuck Leffler

Signature:

Date & Phone#: 1-3-23, 541-990-1907