



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.28	OFF			Y
2	8.33	OFF			Y
3	8.35	OFF			Y
4	8.37	OFF			Y
5	8.38	OFF			Y
6	8.39	OFF			Y
7	8.17	OFF			Y
8	8.42	OFF			Y
9	8.44	OFF			Y
10	8.45	OFF			Y
11	8.44	OFF			Y
12	8.47	OFF			Y
13	8.46	OFF			Y
14	8.45	OFF			Y
15	8.44	OFF			Y
16	8.44	OFF			Y
17	8.45	OFF			Y
18	7.97	OFF			Y
19	7.96	OFF			Y
20	8.16	OFF			Y
21	8.35	OFF			Y
22	8.46	OFF			Y
23	8.54	OFF			Y
24	8.42	OFF			Y
25	8.27	OFF			Y
26	8.28	OFF			Y
27	8.30	OFF			Y
28	8.31	OFF			Y
29	8.28	OFF			Y
30	8.28	OFF			Y
31	8.30	OFF			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: January 2023

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphosphate)

Sili (Silicate)

* Plant was offline during entire month.
 8/2/23

Print Name: Scott LaRoque
Signature: [Signature]
Date & Phone#: 2/7/23, 541-791-0175