



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.36	19.5			Y
2	8.36	20.2			Y
3	7.97	24.3			Y
4	8.17	24.7			Y
5	8.12	23.5			Y
6	8.14	21.5			Y
7	8.14	OFF			Y
8	8.12	OFF			Y
9	7.90	OFF			Y
10	7.84	OFF			Y
11	8.02	OFF			Y
12	8.02	OFF			Y
13	8.21	OFF			Y
14	8.22	20.0			Y
15	8.21	21.5			Y
16	8.17	OFF			Y
17	8.20	OFF			Y
18	8.25	19.2			Y
19	8.24	25.9			Y
20	8.17	25.0			Y
21	8.12	25.9			Y
22	8.11	28.8			Y
23	8.13	23.9			Y
24	8.17	OFF			Y
25	8.19	23.7			Y
26	8.20	25.0			Y
27	8.21	OFF			Y
28	8.18	OFF			Y

<<Have minimums been met for this day?

ENTRY POINT
PWS ID: 4100012 A
System Name: Albany
Entry Point: Vine Street Drinking Water Plant
Sample Period: February 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality
Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Scott LaRoque
Signature: [Signature]
Date & Phone#: 3/10/23, 541 791-0175