



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.19	OFF			Y
2	8.23	OFF			Y
3	8.28	26.4			Y
4	8.30	OFF			Y
5	8.21	25.2			Y
6	8.35	27.5			Y
7	8.44	27.2			Y
8	8.38	27.7			Y
9	8.33	24.0			Y
10	8.30	27.6			Y
11	8.30	26.9			Y
12	8.29	26.1			Y
13	8.25	25.9			Y
14	8.23	25.1			Y
15	8.15	26.1			Y
16	8.12	25.4			Y
17	8.17	OFF			Y
18	8.22	26.0			Y
19	8.18	26.9			Y
20	8.23	OFF			Y
21	8.33	OFF			Y
22	8.32	25.5			Y
23	8.31	OFF			Y
24	8.37	OFF			Y
25	8.38	24.6			Y
26	8.34	24.5			Y
27	8.24	26.9			Y
28	8.23	OFF			Y
29	8.29	OFF			Y
30	8.42	OFF			Y
31	8.46	OFF			Y

<<Have minimums been met for this day?

ENTRY POINT
PWS ID: 4100012 A
System Name: Albany
Entry Point: Vine Street Drinking Water Plant
Sample Period: March 2023
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Scott LaRoque

Signature: [Handwritten Signature]

Date & Phone#: 4/7/2023, 541 791 0175

Send to DWP within 10 days after end of sample period