



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Sili | Y/N |
|-----|------|------|------|------|-----|
| 1 | 8.51 | OFF | | | Y |
| 2 | 8.49 | OFF | | | Y |
| 3 | 8.46 | 25.9 | | | Y |
| 4 | 8.40 | 23.6 | | | Y |
| 5 | 8.29 | 22.7 | | | Y |
| 6 | 8.22 | 24.2 | | | Y |
| 7 | 8.15 | 21.7 | | | Y |
| 8 | 8.04 | 16.6 | | | N |
| 9 | 7.95 | 26.5 | | | Y |
| 10 | | OFF | | | |
| 11 | | OFF | | | |
| 12 | | OFF | | | |
| 13 | 8.08 | 27.3 | | | Y |
| 14 | 8.07 | 24.2 | | | Y |
| 15 | 8.09 | 24.5 | | | Y |
| 16 | 8.10 | 26.2 | | | Y |
| 17 | 8.13 | 26.3 | | | Y |
| 18 | 8.15 | 26.0 | | | Y |
| 19 | 8.14 | 25.7 | | | Y |
| 20 | 8.20 | 19.9 | | | Y |
| 21 | 8.18 | 22.8 | | | Y |
| 22 | 8.11 | 27.5 | | | Y |
| 23 | 7.95 | 24.5 | | | Y |
| 24 | 7.82 | 24.8 | | | Y |
| 25 | 7.85 | OFF | | | Y |
| 26 | 8.06 | OFF | | | Y |
| 27 | 8.15 | 24.5 | | | Y |
| 28 | 8.20 | 27.7 | | | Y |
| 29 | 8.22 | 24.3 | | | Y |
| 30 | 8.20 | 20.7 | | | Y |

<<Have minimums been met for this day?

ENTRY POINT
PWS ID: 4100012 A
System Name: Albany
Entry Point: Vine Street Drinking Water Plant
Sample Period: April 2023
Month/Year

Number of excursions* during this month: 1

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality
Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Scott LaRoque

Signature: [Signature]

Date & Phone#: 5/10/23, 541 791 0175