



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.14	23.5			Y
2	8.16	22.7			Y
3	8.21	OFF			Y
4	8.19	22.4			Y
5	8.17	21.7			Y
6	8.14	22.0			Y
7	8.16	19.0			Y
8	8.16	22.8			Y
9	8.13	23.1			Y
10	8.13	OFF			Y
11	8.19	25.4			Y
12	8.17	22.3			Y
13	8.10	23.0			Y
14	8.08	21.9			Y
15	8.04	23.6			Y
16	8.02	21.7			Y
17	8.06	22.3			Y
18	8.08	21.7			Y
19	8.12	21.0			Y
20	8.15	21.0			Y
21	8.16	24.7			Y
22	8.17	22.9			Y
23	8.26	23.9			Y
24	8.26	23.7			Y
25	8.22	23.1			Y
26	8.15	22.8			Y
27	8.10	19.6			Y
28	8.09	22.9			Y
29	8.10	23.4			Y
30	8.08	23.1			Y
31	8.10	22.1			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: May 2023

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Scott LaRogue

Signature: [Signature]

Date & Phone#: 6/6/23, 541 791 0775