



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.16	20.9			Y
2	8.15	21.7			Y
3	8.10	22.1			Y
4	8.12	22.2			Y
5	8.10	24.2			Y
6	8.08	23.5			Y
7	7.99	21.6			Y
8	8.00	23.8			Y
9	8.12	22.6			Y
10	8.21	23.7			Y
11	8.20	23.4			Y
12	8.12	22.1			Y
13	8.05	21.5			Y
14	8.06	22.3			Y
15	8.11	22.9			Y
16	8.11	22.9			Y
17	8.10	22.4			Y
18	8.06	22.5			Y
19	8.08	23.4			Y
20	8.10	24.8			Y
21	8.14	22.9			Y
22	8.16	23.5			Y
23	8.08	23.6			Y
24	8.05	22.2			Y
25	8.05	27.4			Y
26	8.07	23.5			Y
27	8.06	25.4			Y
28	8.02	24.5			Y
29	8.01	18.3			Y
30	7.96	21.3			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: June 2023

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphosphate)

Sili (Silicate)

Print Name: SCOTT LAROQUE

Signature: [Signature]

Date & Phone#: 7/6/23, 541 741 0775