



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.93	23.5			Y
2	7.96	23.6			Y
3	7.94	24.0			Y
4	8.07	27.2			Y
5	8.18	24.3			Y
6	8.14	23.9			Y
7	8.23	24.5			Y
8	8.30	24.1			Y
9	8.32	27.1			Y
10	8.30	26.7			Y
11	8.33	23.9			Y
12	8.34	26.4			Y
13	8.31	25.3			Y
14	8.31	24.8			Y
15	8.27	24.2			Y
16	8.29	26.3			Y
17	8.31	26.4			Y
18	8.31	27.5			Y
19	8.29	27.3			Y
20	8.21	24.6			Y
21	8.16	24.0			Y
22	8.21	24.6			Y
23	8.23	23.9			Y
24	8.22	25.1			Y
25	8.26	24.7			Y
26	8.29	24.3			Y
27	8.31	24.2			Y
28	8.29	25.0			Y
29	8.25	24.2			Y
30	8.28	25.9			Y
31	8.30	26.8			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: July 2023

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Scott LaRoque

Signature: [Signature]

Date & Phone#: 8/9/23, 541 791 0175

Send to DWP within 10 days after end of sample period