



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

| Day | pH   | Alk  | Phos | Sili | Y/N |
|-----|------|------|------|------|-----|
| 1   | 8.30 | 26.0 |      |      | Y   |
| 2   | 8.28 | 24.5 |      |      | Y   |
| 3   | 8.28 | 25.3 |      |      | Y   |
| 4   | 8.28 | 24.1 |      |      | Y   |
| 5   | 8.26 | 23.8 |      |      | Y   |
| 6   | 8.28 | 24.8 |      |      | Y   |
| 7   | 8.30 | 27.7 |      |      | Y   |
| 8   | 8.29 | 26.1 |      |      | Y   |
| 9   | 8.28 | 26.0 |      |      | Y   |
| 10  | 8.27 | 23.8 |      |      | Y   |
| 11  | 8.25 | 25.5 |      |      | Y   |
| 12  | 8.25 | 23.4 |      |      | Y   |
| 13  | 8.27 | 25.2 |      |      | Y   |
| 14  | 8.23 | 26.0 |      |      | Y   |
| 15  | 8.22 | 26.1 |      |      | Y   |
| 16  | 8.20 | 22.9 |      |      | Y   |
| 17  | 8.22 | 24.4 |      |      | Y   |
| 18  | 8.26 | 23.8 |      |      | Y   |
| 19  | 8.30 | 25.3 |      |      | Y   |
| 20  | 8.34 | 23.6 |      |      | Y   |
| 21  | 8.34 | 25.7 |      |      | Y   |
| 22  | 8.36 | 23.9 |      |      | Y   |
| 23  | 8.35 | 23.3 |      |      | Y   |
| 24  | 8.36 | 23.6 |      |      | Y   |
| 25  | 8.30 | 18.8 |      |      | Y   |
| 26  | 8.30 | 23.7 |      |      | Y   |
| 27  | 8.34 | 25.4 |      |      | Y   |
| 28  | 8.35 | 23.4 |      |      | Y   |
| 29  | 8.35 | 24.6 |      |      | Y   |
| 30  | 8.37 | 23.4 |      |      | Y   |
| 31  | 8.37 | 23.6 |      |      | Y   |

<<Have minimums been met for this day?

**ENTRY POINT**

**PWS ID: 4100012 A**

**System Name:** Albany

**Entry Point:** Vine Street Drinking Water Plant

---

**Sample Period:** August 2023

**Month/Year**

**Number of excursions\* during this month:** 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality**

**Parameters as set by State:**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

**Print Name:** Chris Germond

**Signature:** Chris Germond

**Date & Phone#:** 9/8/2023 541-704-2309

Send to DWP within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405