



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.17	23.7			Y
2	8.26	23.5			Y
3	8.22	24.1			Y
4	8.22	OFF			Y
5	8.22	24.8			Y
6	8.26	24.1			Y
7	8.18	24.4			Y
8	8.17	24.2			Y
9	8.18	25.2			Y
10	8.24	25.5			Y
11	8.26	OFF			Y
12	8.28	OFF			Y
13	8.28	OFF			Y
14	8.29	25.2			Y
15	8.40	27.9			Y
16	8.35	27.8			Y
17	8.21	30.9			Y
18	7.99	27.8			Y
19	8.07	28.0			Y
20	8.21	20.1			Y
21	8.29	OFF			Y
22	8.19	21.5			Y
23	8.10	27.5			Y
24	8.12	29.5			Y
25	8.11	27.0			Y
26	8.16	OFF			Y
27	8.16	OFF			Y
28	8.18	OFF			Y
29	8.15	OFF			Y
30	8.16	30.5			Y
31	8.23	30.7			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: October 2023

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 11/8/23 541-764-2307

Send to DWP within 10 days after end of sample period