



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.24	OFF			Y
2	8.24	27.1			Y
3	8.26	28.1			Y
4	8.10	29.3			Y
5	8.04	29.6			Y
6	8.05	23.4			Y
7	8.07	28.5			Y
8	8.10	OFF			Y
9	8.09	30.4			Y
10	8.12	29.8			Y
11	8.04	26.8			Y
12	8.04	27.2			Y
13	8.03	24.5			Y
14	8.04	26.8			Y
15	8.08	OFF			Y
16	8.05	27.2			Y
17	8.08	25.2			Y
18	8.03	24.5			Y
19	8.02	OFF			Y
20	8.05	28.8			Y
21	8.06	24.3			Y
22	8.08	24.3			Y
23	8.08	25.8			Y
24	8.13	24.5			Y
25	8.12	28.1			Y
26	8.05	28.5			Y
27	8.01	26.0			Y
28	8.00	29.4			Y
29	7.96	OFF			Y
30	7.98	28.9			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: November 2023

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 12/7/23