



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.99	27.6			Y
2	8.00	28.5			Y
3	7.97	28.6			Y
4	7.92	25.4			Y
5	7.83	25.0			Y
6	7.80	23.4			Y
7	7.87	25.9			Y
8	7.97	27.0			Y
9	8.04	26.5			Y
10	8.15	27.7			Y
11	8.17	28.6			Y
12	8.04	24.5			Y
13	8.00	OFF			Y
14	8.02	23.5			Y
15	8.08	20.7			Y
16	8.05	OFF			Y
17	8.09	19.8			Y
18	8.14	26.0			Y
19	8.10	23.2			Y
20	8.10	20.8			Y
21	8.18	20.4			Y
22	8.11	19.4			Y
23	8.12	22.9			Y
24	8.14	21.4			Y
25	8.20	22.1			Y
26	8.15	18.4			Y
27	8.03	18.0			Y
28	8.01	22.5			Y
29	8.08	26.1			Y
30	8.07	26.1			Y
31	8.09	28.8			Y

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

---

Sample Period: December 2023

Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality**

**Parameters as set by State:**

pH 7.8

Alk 18.0 (Alkalinity)

PO4   (Orthophosphate)

Sili   (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 1/5/2024 541-764-2309