



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.34	24.5			Y
2	8.34	20.0			Y
3	8.29	27.5			Y
4	8.24	23.4			Y
5	8.12	24.5			Y
6	8.21	20.3			Y
7	8.24	23.8			Y
8	8.13	24.1			Y
9	8.15	25.0			Y
10	8.18	24.5			Y
11	8.15	OFF			Y
12	8.14	21.7			Y
13	8.12	21.3			Y
14	8.14	23.2			Y
15	8.07	23.5			Y
16	8.14	23.1			Y
17	8.14	26.5			Y
18	8.10	23.8			Y
19	8.12	24.4			Y
20	8.13	23.8			Y
21	8.11	24.3			Y
22	8.11	OFF			Y
23	8.10	27.0			Y
24	8.03	25.4			Y
25	8.11	25.3			Y
26	8.12	25.8			Y
27	8.19	25.3			Y
28	8.21	OFF			Y
29	8.15	25.7			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: February 2024

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Scott LaRoque

Signature: [Handwritten Signature]

Date & Phone#: 3/5/24, 541 570 5719