



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	8.19	OFF			Y
2	8.12	27.0			Y
3	8.11	26.0			Y
4	8.12	27.9			Y
5	8.14	27.4			Y
6	8.16	29.2			Y
7	8.17	27.1			Y
8	8.20	26.5			Y
9	8.18	25.2			Y
10	8.13	OFF			Y
11	8.12	OFF			Y
12	8.06	OFF			Y
13	8.11	22.1			Y
14	8.16	26.4			Y
15	8.14	24.9			Y
16	8.11	26.2			Y
17	8.08	26.6			Y
18	8.08	OFF			Y
19	8.12	22.5			Y
20	8.17	24.3			Y
21	8.17	25.7			Y
22	8.20	OFF			Y
23	8.15	OFF			Y
24	8.10	OFF			Y
25	8.11	OFF			Y
26	8.10	OFF			Y
27	8.09	OFF			Y
28	8.08	OFF			Y
29	8.06	OFF			Y
30	8.01	OFF			Y
31	8.01	OFF			Y

<<Have minimums been met for this day?

**ENTRY POINT**

**PWS ID: 4100012 A**

**System Name:** Albany

**Entry Point:** Vine Street Drinking Water Plant

**Sample Period:** March 2024

**Month/Year**

**Number of excursions\* during this month:** 0  
 (Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

**Print Name:** St. LaRoque

**Signature:** [Signature]

**Date & Phone#:** 4/4/24, 541 570 5719