



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.01	OFF			Y
2	8.01	OFF			Y
3	8.01	OFF			Y
4	8.00	OFF			Y
5	7.98	OFF			Y
6	7.97	OFF			Y
7	7.98	OFF			Y
8	7.98	OFF			Y
9	7.97	OFF			Y
10	7.95	OFF			Y
11	7.96	OFF			Y
12	7.97	OFF			Y
13	7.96	OFF			Y
14	7.93	OFF			Y
15	7.90	OFF			Y
16	8.01	21.7			Y
17	8.15	27.3			Y
18	8.10	OFF			Y
19	8.11	24.5			Y
20	8.11	24.0			Y
21	8.11	22.1			Y
22	8.14	22.7			Y
23	8.12	OFF			Y
24	8.11	OFF			Y
25	8.11	OFF			Y
26	8.09	23.6			Y
27	8.10	23.1			Y
28	8.15	23.2			Y
29	8.14	OFF			Y
30	8.10	OFF			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: April 2024

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO₄ (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 5/19/2024 591-970-0748