



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	8.09	OFF			Y
2	8.06	OFF			Y
3	8.08	OFF			Y
4	8.03	OFF			Y
5	8.00	OFF			Y
6	7.97	OFF			Y
7	7.92	18.6			Y
8	7.95	24.4			Y
9	7.90	22.5			Y
10	7.95	23.0			Y
11	7.94	20.8			Y
12	7.99	22.5			Y
13	8.09	23.5			Y
14	8.05	OFF			Y
15	8.09	OFF			Y
16	8.22	27.6			Y
17	8.32	28.9			Y
18	8.35	24.9			Y
19	8.24	OFF			Y
20	8.12	26.8			Y
21	8.20	21.2			Y
22	8.28	24.4			Y
23	8.30	24.3			Y
24	8.30	24.9			Y
25	8.21	OFF			Y
26	8.21	24.3			Y
27	8.29	OFF			Y
28	8.23	OFF			Y
29	8.21	25.5			Y
30	8.28	23.9			Y
31	8.31	24.5			Y

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: May 2024

Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH 7.8

Alk 18.0 (Alkalinity)

PO4   (Orthophosphate)

Sili   (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 6/7/2021 541-704-2309