



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	8.22	25.5			Y
2	8.20	25.9			Y
3	8.23	23.8			Y
4	8.26	25.4			Y
5	8.21	25.9			Y
6	8.20	27.0			Y
7	8.13	25.3			Y
8	8.11	24.0			Y
9	8.07	24.0			Y
10	8.08	26.0			Y
11	8.12	24.2			Y
12	8.15	23.4			Y
13	8.18	23.7			Y
14	8.21	24.6			Y
15	8.22	24.8			Y
16	8.22	24.9			Y
17	8.16	28.0			Y
18	8.16	25.0			Y
19	8.16	27.8			Y
20	8.10	24.8			Y
21	8.05	24.1			Y
22	8.07	24.6			Y
23	8.14	26.2			Y
24	8.13	23.2			Y
25	8.10	20.9			Y
26	8.12	28.2			Y
27	8.12	24.2			Y
28	8.12	24.6			Y
29	8.14	23.9			Y
30	8.19	25.7			Y
31	8.20	26.5			Y

<<Have minimums been met for this day?

**ENTRY POINT**  
**PWS ID: 4100012 A**  
**System Name: Albany**  
**Entry Point: Vine Street Drinking Water Plant**  
**Sample Period: July 2024**  
Month/Year

**Number of excursions\* during this month: 0**  
 (Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months: 0**  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

**Print Name:** Chris Germond  
**Signature:** Chris Germond  
**Date & Phone#:** 8/2/2024 50704-2309